

Appendix H

COLIFORM MONITORING PLAN

CITY OF GOLD BAR

COLIFORM MONITORING PLAN

SYSTEM INFORMATION:

Washington State I.D. 28300Y

SOURCE:

S01 - Well 1 Section 6
 Township 27
 Range 9E

S02 - Well 2 Section 6
 Township 27
 Range 9E

S03 - Well 3 Section 6
 Township 27
 Range 9E

STORAGE:

1 (one) 250,000 gallon storage reservoir.

1 (one) 100,000 gallon storage reservoir.

1 (one) 250,000 gallon storage reservoir (to be
constructed and completed in 1993).

TREATMENT:

S01/S02/S03 disinfected by injection of liquid chlorine
at manifold prior to entering distribution system.

S01 7.5hp submersible pump (60 gpm)

S02 10hp submersible pumpe (120 gpm)

S03 20hp submersible pump (180 gpm)

Population: 1247

Connection: 461

ROUTINE SAMPLING: 2 samples per month.

Samples drawn first week of each month.

Samples are taken to Snohomish County Health Department
3020 Rucher
Everett, Wa. 98201
(206)330-5270

Repeat samples are hand delivered A.S.A.P.

Specific Sample Sites:

Site 1

- a. Water Department Office 501 5th st.

Site 2

- a. City Hall 408 Orchard

Site 3

- a. Police Station 505 Lewis Street

MONTH	SITE		
Jan	1		
Feb		2	
Mar			3
Apr	1		
May		2	
June			3
July	1		
Aug		2	
Sept			3
Oct	1		
Nov		2	
Dec			3